
**HUBERT WELL 2 GENERATOR IMPROVEMENT PROJECT
ADDENDUM #2
AUGUST 16, 2021**

TO ALL RESPONDENTS:

This addendum is to establish a new Bid due date as well as answer the following question and make corrections to the Scope of Work.

New Bid Due Date:

August 24, 2021 at 2:00 PM

Question 1:

Does ONWASA want to remove the existing manual transfer switch (MTS)?

Answer:

No. Leave the existing MTS and Appleton receptacle, and add the new Automatic Transfer Switch (ATS) in line. Intent is to provide the capability for two (2) alternate power sources and one commercial power feed. The Contractor shall provide and install an additional rack as required.

Correction 1:

Scope of Service, 1. General Requirements, item a.

Should read:

Work shall be performed in accordance with all applicable State and Local Codes and regulations governing this project. It shall be the responsibility of the Contractor to design and wire the generator and other components as necessary to meet these requirements and function as intended.

Acknowledge receipt of this Addendum in the space provided in the Bid Pricing Sheet.

END OF ADDENDUM #2