
**HUBERT WELL 2 GENERATOR IMPROVEMENT PROJECT
ADDENDUM #3
AUGUST 18, 2021**

TO ALL RESPONDENTS:

This addendum is to answer the following question.

Question:

Should the ATS inline be installed before or after the existing MTS?

Answer:

The ATS inline can be installed either before or after the existing MTS.

Acknowledge receipt of this Addendum in the space provided in the Bid Pricing Sheet.

END OF ADDENDUM #3